

CITY OF STANTON

ANNUAL DRINKING WATER QUALITY REPORT

2019

We are pleased to present to you, this year's Annual Water Quality Report. This report is designed to inform you about the quality of your drinking water, and the services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process, while protecting our water resources. We are committed to ensuring the quality of your water.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling EPA's Safe Drinking Water Hotline (1-800-426-4791)

Some people may be more vulnerable to contaminants in drinking water than the general population. Immune-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infections by Cryptosporidium and other microbial contaminants are available by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791)

Our water source is groundwater (wells) As water travels over the surface of the land and into the ground, it dissolves naturally occurring minerals, and in some cases, radioactive material. Water can also pick up substances that are a result of human and animal activity

Your water comes from two (2) groundwater wells approximately 201' deep, located at 601 New Street. The State of Michigan performed an assessment of our source water in 2015, to determine the susceptibility, or the relative potential of contamination. The susceptibility is on a six-tiered scale from "very low" to "very high" based primarily on geologic sensitivity, water chemistry, and contaminant sources. The susceptibility of our source water is "moderate".

Contaminants that may be present in source water before treatment include:

*Microbial contaminants, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

*Inorganic contaminants, such as salts and metals, which are naturally occurring or result from urban storm water run-off, accidental industrial or domestic wastewater discharges, oil and gas productions, mining or farming.

*Pesticides and herbicides, which may come from a variety of sources such as agricultural and residential uses.

*Radioactive contaminants, which are naturally occurring.

*Organic chemical contaminants, including synthetic and volatile organic chemicals which are by-products of industrial processes and petroleum productions. And can also come from gas stations, urban storm water run-off, and septic systems.

In order to ensure the tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by Public Water Systems. We treat our water according to EPA's regulations. Food and Drug Administration's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

If you have questions regarding this report or concerning your water utility, please contact James Blum at (1-989-831-9332). We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second and fourth Tuesday's of the month at 7:00 p.m. in the Community Room at City Hall. 225 South Camburn Street, Stanton, MI

WATER QUALITY DATA

The City of Stanton routinely monitors for contaminants in your drinking water according to Federal and State Laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2019.

Terms and abbreviations used:

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in Drinking water below which there is no known expected risk to health. MCLG's allow for a margin of safety.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible, using the best available treatment technology.

Action Level (AL): The concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.

N/A: not applicable ***nd:** not detectable at testing limit ***ppb:** parts per billion or Micrograms per liter ***ppm:** parts per million or Milligrams per liter ***pci:** Pico curies per liter (measurement of radiation).

Contaminants

contaminant	MCLG	MCL	AL	Your water	Sample date	Violations
Copper	1300 ppb	1300 ppb	1300 ppb	300 ppb	2019	no
Lead	0 ppb	15 ppb	15 ppb	2 ppb	2019	no
Fluoride	--	4 ppm	4 ppm	0	2019	no
Nitrate	--	10 ppm	10 ppm	0	2019	no
Total						
Trihalomethanes	--	0.080 ppm	0.080 ppm	0	2019	no
Arsenic	--	0.010 ppm	0.010 ppm	0	2019	no
Sodium	--	--	--	8 ppm	2019	no

Lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Stanton is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in drinking water, you may wish to have you water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at (1-800-426-4791) or at <http://epa.gov/drink/info/lead>

*none of the 10 sites sampled for copper or lead were above the action level

Chlorine residual range of detection 2019: .30-1.50 ppm-----MRDL/MCL 4.0 ppm

Chlorine running annual average 2019: .85 ppm

Chlorine Residuals: Maximum Residuals Disinfectant Level, MRDL means the highest level of a disinfectant allowed in drinking water (4.0 ppm). There is convincing evidence that an addition of disinfectant is necessary for control of microbial contaminants. Maximum Residual Disinfectant Level Goal, or MRDLG, means the level of drinking water disinfectant below which there is no known or expected risk to health. MCLG's do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Contaminant sources:

Copper: corrosion of household plumbing system, erosion of natural deposits

Lead: corrosion of household plumbing system, erosion of natural deposits

Fluoride: erosion of natural deposits, water additive which promotes strong teeth, discharge from fertilizer, aluminum factories

Nitrate: run-off from fertilizer use, leaking from septic tanks, sewage, erosion of natural deposits

Total Trihalomethanes: by-product of drinking water disinfection

Arsenic: erosion of natural deposits, run-off from orchards, run-off from glass and electronics production wastes

Sodium: erosion of natural deposits

MCL's are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one in a million chance of having the described health effect.

As you can see by the table, our system had no MCL violations. We are proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected. The EPA has determined that your water is safe at these levels.

Thank you for allowing us to continue to provide your family with clean, quality water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. These improvements are sometimes reflected as rate structure adjustments. Thank you for understanding.